

Vittneame - Er tel. - Your ref. Kirifeame - Er brev - Your letter

JOUKO LASSILA 1997 09 23

Käsitleiy - Handläggning - Handling

TA-LABORATORY

Luettelonitrimnumero - Reg. nummer - Reg.nr

197206-01

Tehkäänantaja - Uppdragsgivare - Applicant

040252

Fibox Oy Ab

014169

Fibox Oy Ab

Valmistaja/Valmistuttaja - Tillverkare/Tillverkad for - Manufacturer/Manufactured for

PL 16
02421 JORVAS

FINLAND

I N V E S T I G A T I O N R E P O R T
84800 BOX, FOR SURFACE MOUNTING

01 MODEL SOLID PC 563818 G/T "FIBOX" "
VOLTAGE V 690
DEGREE OF PROTECTION IP68
MATERIAL/THICKNESS MM PC
OTHER DETAILS Dimensions: 560x380x180 mm.

Degrees of protection provided by enclosures (IP Code). Testing for IP-classification according to the standard EN 60529:1991/IEC 529:1989.

Test conditions:

The box was immersed for 72h in water and the water pressure outside the box was 30 kPa, which means the pressure about 3 m below the surface of the water.

Test results:

No remarks, The box comply with the standard for the class IP68 at the immersion depth of max. three meters.

For more information on this test result, please contact Mr Raimo Ristimäki or Antero Pitronen.

Helsinki 1997-10-21

FIMKO LTD.

T. Pele

Postiosoite: PL 30 FIN-00211 HELSINKI
Postadress: Box 30 FIN-00211 HELSINGFORS
Postal address: PB 30 FIN-00211 HELSINKI

Katuosoite: Särkkinleentie 3, HELSINKI
Gatuadress: Mörtnäsvägen 3, HELSINGFORS
Street address: Särkkinleentie 3, HELSINKI

(09) 696 361 Kio
+358-9-696 361 Kl. 9.00-15.00
cl

Telefax (09) 692 5474
Fax +358-9-6925474